



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", तिसरी मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-४४० ००१ महाराष्ट्र  
Regional Office : "Narang Tower", 3<sup>rd</sup> Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur-440 001 Maharashtra  
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला  
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/NH-361/HT Line Power Grid/UT/2020-21/2178

Date: 29.12.2020

### Invitation of Public Comments

**Sub:** Proposal for grant of permission for crossing of diversion of existing 400 KV D/C (Quad Bundle), Raipur Wardha Transmission Line of Power Grid Corporation of India Limited on Wardha-Yavatmal Nanded BG Line of Central Railway-Reg.

**Ref.:** (i) PD, PIU-Yavatmal Lr. No. NHAI/PIU/YTL/NH-361/YW/Crossing/2019/2011 dated 12.09.2020

(ii) Power Grid Corporation of India Ltd Wardha Letter No. WR-1/WRD/AM/TLM/RW/NH-361 crossing/1178 Dated 13.06.2019.

\* \* \*

It is to inform all concern that Power Grid Corporation of India Ltd vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Yavatmal has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that Power Grid Corporation of India Ltd along on Wardha-Yavatmal Nanded Section of NH-361 in the State of Maharashtra as follows:

- Crossing of 400 KV DC (Quad Bundle), Raipur Wardha Transmission Line (/H Crossing) from Km. 460.875 to Km. 461.875 on Wardha- Yavatmal Nanded section of NH-361 in the State of Maharashtra.
- Height of the vertical clearance - 19.8 m.
- Distance of Horizontal clearance - 129.20 m ( From centre to Tower no. 985B ) and 107.8 m ( From centre to Tower No. 986B)
- Angle of Crossing at 67° 07' 00" to the NH-361

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 28.01.2016 due to above transmission line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 28.01.2021, beyond due date, no comments/ objections will be accepted.

मुख्यालय : जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075  
Head Office : G-5 & 6, Sector-10, Dwarka, New Delhi - 110 075

**The Regional Officer,**  
Regional Office - Nagpur  
National Highways Authority of India,  
'Narang Towers', 3<sup>rd</sup> Floor,  
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),  
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra  
Tel : 0712-2520091  
Email : ronagpur@nhai.org

*N. Wadetwar*  
*29.12.20*

(Naresh Y. Wadetwar)  
General Manager (Tech.)  
NHAI, RO, Nagpur

Copy to: (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website  
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi  
[mansoor@nic.in]

- for uploading in Ministry's website