



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
क्षेत्रीय कार्यालय, चेन्नई / Regional Office, Chennai
'श्री टावर' 3rd मंजिल, DP-34 (SP), इंडस्ट्रीयल एस्टेट, गिण्डि, चेन्नई - 600 032
'SRI TOWER', 3rd Floor, DP-34 (SP), Industrial Estate, Guindy, Chennai - 600 032.

दूरभाष/Tele : 91-44-2225 2635
फैक्स/Fax : 91-44-2225 2636
ई-मेल/ E-mail: rochennai@nhai.org

NHAI/11019/15/2009/RO Chennai/ 2153

28th July, 2021

Invitation of Public Comments

Sub: NHAI, RO Chennai - PIU - Coimbatore - Six laning from Km 102.035 to Km 144.680 on the Chengapalli to start of Coimbatore bypass and 4-laning from Km 170.880 to Km 183.010 on end of Coimbatore bypass to TN/Kerala Border section of NH-47 (New No.544) - Proposal seeking permission by TWAD for laying underground water pipeline along the road between Km 105/622 and 115/475 (LHS & RHS) 10572m & 6 Nos. crossing (348m) - Approval Requested - Reg.

The subject proposal is requesting permission for laying / crossing of Underground water pipeline on NH-544 as under:

Sl.No	Chainage	Length (in meters)	Size of pipeline	Method of Laying
1.	Km 105/622 to Km 106/240 (RHS)	618m	75mm dia HDPE pipe	Open Trench Method
2.	Km 107/290 to Km 108/088 (RHS)	798m	110mm dia HDPE pipe	
3.	Km 109/628 to Km 110/275 (RHS)	647m	125mm dia HDPE pipe	
4.	Km 112/650 to Km 113/220 (RHS)	570m	200mm dia HDPE pipe	
5.	Km 112/650 to Km 115/475 (RHS)	2825m	350mm dia MS pipe	
6.	Km 106/116 to Km 106/280 (LHS)	164m	75mm dia HDPE pipe	
7.	Km 107/700 to Km 108/088 (LHS)	388m	110mm dia HDPE pipe	
8.	Km 108/088 to Km 109/628 (LHS)	1540m	75MM dia HDPE pipe	
9.	Km 109/628 to Km 110/640 (LHS)	1012m	125mm dia HDPE pipe	
10.	Km 110/640 to Km 112/650 (LHS)	2010m	200mm dia HDPE pipe	
11.	Crossing at Km 106/176	58m	75mm dia with 140mm dia casing pipe	HDD Method
12.	Crossing at Km 110/000	58m	110mm dia with 225mm dia casing pipe	
13.	Crossing at Km 110/000	58m	125mm dia with 250mm dia casing pipe	
14.	Crossing at Km 110/220	58m	63mm dia with 125mm dia casing pipe	
15.	Crossing at Km 112/650	58m	200mm dia with 450mm dia casing pipe	
16.	Crossing at Km 112/650	58m	350mm dia with 630mm dia casing pipe	

2. The available width of ROW is 60m (30 + 30) and it is proposed to lay the pipeline in the utility corridor and one number road crossing

3. M/s. TWAD Board, Namakkal has furnished an undertaking to move the utility line for any work of improvement or repairs to the road, If NHAI considers if necessary in future, it will be carried out as desired by the NHAI at their cost within a reasonable time (not exceeding 60 days) of the intimation given. Further, the applicant has furnished the undertaking for payment of rent / fee as mentioned in the Ministry's Circular No. RW/NH-33044/29/2015-S&R dated 22.11.2016 as when asked by NHAI.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the proposal submitted by M/s. TWAD Board, Tiruppur will be made available for 30 days seeking public comments/objection and shall be furnished within 30 days from the day of closure of public objections.

In view of the above, comments of the public on the above proposal are invited and may be sent to the below mentioned address:

The Regional Officer
National Highways Authority of India
(Ministry of Road, Transport & Highways)
SRI Tower, 3rd floor
DP - 34 (SP), Industrial Estate,
Guindy, Chennai - 600 032

Yours faithfully



(S. Meenakshi Sundaram)
DGM (T)

For Regional Officer, NHAI, Chennai

Copy to:

1. NHAI website
2. The NIC, New Delhi - for uploading in the Ministry's website
3. PD, NHAI, Coimbatore - For information.